

AMENDMENT OF SOLICITATION

1. AMENDMENT NO. 01

2. EFFECTIVE DATE – 07/23/2026

3.
PAGE 1 of 1

4. ISSUED BY: **Southern Ohio Cleanup Company LLC**
P.O. Box 368
3930 US Route 23 South
Piketon, OH 45661

5. NAME AND ADDRESS OF CONTRACTOR (*Name, street, county, state & zip code*)

All Offeror(s)

6. AMENDMENT OF (RFP)
SOLICITATION NO.
SOCCo26SC34596

DATE
7/23/2026

7.
The above numbered solicitation is amended as set forth in Item 8. The hour and date specified for receipt of Offers X is extended is not extended.
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods:

(a) By completing Items 5 and 9, and returning one (1) copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or e-mail which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by e-mail or letter, provided each e-mail or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

8. DESCRIPTION OF AMENDMENT

Except as provided herein, all terms and conditions of the document remain unchanged and in full force and effect.

Section L.3 has been updated. New Proposal Due Date is Wednesday, July 29, 2026 @9:00 AM

Please see the answers to questions received provided in the attached:

9A. NAME AND TITLE OF SIGNER (<i>Type or print</i>)		10A. Southern Ohio Cleanup Company LLC Dwayne Newsom – Contract Specialist	
9B. CONTRACTOR/OFFEROR <i>(Signature of person authorized to sign)</i>	9C. DATE SIGNED	10B. <i>(Signature)</i>	10C. DATE SIGNED 07/23/2026

	Questions	Answers
1	The SOW Section 3.1.2 states, "<i>Contractor will also be responsible for clearing debris, cleaning/repairing roof drains.</i>" Can you clarify that the scope of work for the roofing contractor will be to clear clogged drains to 24" below the roof surface and repair the seal between roof and drain bowl and notify SOCCo if any plumbing issues are identified beyond this that will require a plumber? It is difficult to include pricing for issues that are unknown at this time	This is Acceptable
2	The SOW Exhibit 1 has a construction duration from Mob to Demob of only 72 calendar days, based on the unknown time of year, the decking repair work scope, and size of this project, we request at least a 30 calendar day increase to the onsite period of performance, making the Demobilization 132 Days after NTP and Project Close Out 162 Days after NTP. Note, adhesives will be required to patch any roofing that is removed for deck repairs, and these adhesives have minimum temp/humidity requirements that often cannot be met during winter months.	We will allow a 6 day work week in order to complete the scope within the listed period of performance.
3	Regarding attachment B.1 Contract Document - Section M.3 C, in order to build our Schedule for the proposal, please provide an anticipated NTP date to use for the start of the schedule	8/20/2026
4	The SOW Section 3.2.1.A.3 States, "Repair of metal decking where leaking exists." In order to account for this work scope, can the qty of locations and the assumed total SF of decking to be replaced be provided for bidding purposes?	24 locations 100 SF each location
5	The SOW Section 3.2.1.A.3 States, "<i>Repair of metal decking where leaking exists.</i>" Please confirm the additional work requirements/training that will be required to demo the roofing system above these areas, such as asbestos abatement/respiratory work/RadWorker, etc.	For bid purposes assume ACM and lead present, and RWP required. PPE required will be dependent on the approach selected by the contractor.